

2021 Water Quality Report



The Forsyth County Water & Sewer Department is proud to supply clean, safe, reliable drinking water for all its customers.

In 2020, the year covered by this report, the water from your tap met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. This water quality report details where your water comes from, what it contains and how it compares to standards set by the regulatory agencies.

Questions About Your Water....

SOURCE

Where does our water come from?

The vast majority of Forsyth County's water comes from Lake Lanier and is treated by either Forsyth County or the City of Cumming. A small portion of Forsyth County's water comes from Fulton County, which withdraws water from the Chattahoochee River.

S.W.A.P.

Source Water Assessment Plan

In 2020, the Metropolitan North Georgia Water Planning District completed a Source Water Assessment Plan for Forsyth County that itemized potential sources of water pollution within the Lake Lanier watershed.

Source Water Assessment Plans:

- Delineate the watershed area for each public drinking water source
- Contain an inventory of potential sources of contamination within that watershed
- Determine the susceptibility of the water supply to contamination within the watershed assessment area

The Forsyth County Source Water Assessment Plan is available for review at www.forsythco.com

YOUR WATER

More than 1,300 tests are conducted annually by the Environmental Protection Division (EPD) of the Georgia Department of Natural Resources and Forsyth County to ensure you have safe drinking water. These tests monitor tap water for organisms, minerals and organic substances that could cause disease or other adverse health effects. Testing is done for over 100 different contaminants including bacteria, metals, nitrates and pesticides.

The water quality data shown in the table on the back page lists regulated drinking water contaminants monitored during 2020, the calendar year of this report. Presence of contaminants in water does not necessarily indicate the water poses a health risk.

CONTAMINANTS

What is in our water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's SafeDrinking Water Hotline (1-800-426-4791). Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide similar protection for public health. Sources of drinking water—both tap water and bottled water—include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels through the ground or over the surface of land, it dissolves naturally-occurring minerals and, in some instances, radioactive material. Water also can pick up substances resulting from the presence of animals or from human activity.

The 2021 Water Quality Report is brought to you by the Forsyth County Water and Sewer Department:

110 E. Main Street, Suite 150 | Cumming, Georgia 30040
(770) 781-2160 | forsythco.com

PRECAUTIONS

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as patients with cancer undergoing chemotherapy, those who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their healthcare providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline: 1-800-426-4791.

THE FOLLOWING ARE EXAMPLES OF WATER CONTAMINANTS:



MICROBIAL CONTAMINANTS such as viruses and bacteria come from sewage treatment plants, septic systems, livestock operations and wildlife.



INORGANIC CONTAMINANTS such as salt and metals can be naturally occurring or result from urban storm water runoff, industrial or domestic waste, water discharges, oil and gas production, mining or farming.



PESTICIDES OR HERBICIDES may come from a variety of sources such as agriculture, urban storm water runoff and residential uses.



RADIOACTIVE CONTAMINANTS can be naturally occurring or the result of oil and gas production and mining activities.



ORGANIC CHEMICAL CONTAMINANTS including synthetic and volatile organic chemicals are byproducts of industrial processes and petroleum production. They also can come from gas stations, urban storm water runoff and septic systems.

To receive additional water information, call the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Georgia Water System ID Number GA1170050

Guide to the Data Table

The table below lists all the information required by the Federal Safe Drinking Water Act. To better understand what the table tells you about your drinking water, use the tips to the right:

A+B These columns are the highest levels of each contaminant considered safe in drinking water.

C This column is the average level of each contaminant found in your drinking water during sampling by the County.

D This column is the range of each contaminant level found during sampling by the County.

A B C D WATER QUALITY DATA TABLE

Regulated substance sampled	MCLG	MCL	Your water	Range (low-high)	Sample date	Violation exceeds AL	Typical Source
Fluoride (ppm)	4	4	0.77	0.03-1.48	2020	No	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate/Nitrite (ppm)	10	10	0.33	0.33	2020	No	Runoff from fertilizer use; leaching from septic tanks and sewerage; erosion of natural deposits
Turbidity (NTU)	NA	5	0.086	0.01-0.82	2020	No	Soil runoff
TTHMs [Total Trihalomethanes] (ppb)	NA	80	32.78	14.1-56.1	2020	No	By-product of drinking water chlorination
Total Coliform	0	<5%	0	0	2020	No	Naturally present in the environment
Unregulated substance sampled	MCLG	MCL	Your water	Range (low-high)	Sample date	Violation exceeds AL	Typical Source
Total Organic Carbon (ppm)	NA	NA	1.09	0.91-1.2	2020	No	Plant and animal material
Haloacetic Acid (ppb)	NA	60	33.9	17.2-57.5	2020	No	By-product of drinking water chlorination
Free Chlorine Residue (ppm)	**4	*4	2.78	0.73-2.95	2020	No	Water additive for disinfection
Regulated substance sampled (at the customer's tap)	MCLG	MCL	Your water	90th Percentile	Sample date	Violation exceeds AL	Typical Source
Copper (ppb)	1300	1300	340	340	2018	No	Erosion of natural deposits; leaching; corrosion of household plumbing systems
Lead (ppb)	ND	15	7.7	7.7	2018	No	Corrosion of household plumbing systems; erosion of natural deposits

DUE TO LOW LEVELS OF LEAD AND COPPER IN OUR WATER, THE STATE HAS REDUCED THE FREQUENCY OF TESTING TO EVERY THREE YEARS.

Next Lead/Copper test: Summer 2021

WATER TERMINOLOGY

MAXIMUM CONTAMINANT LEVEL GOAL (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MAXIMUM CONTAMINANT LEVEL (MCL): The highest level of a contaminant allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best treatment technology.

****MAXIMUM RESIDUAL DISINFECTANT LEVEL GOAL (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of using disinfectants to control microbial contaminants.

***MAXIMUM RESIDUAL DISINFECTANT LEVEL (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that adding a disinfectant is necessary to control microbial contaminants.

ACTION LEVEL (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

PARTS PER MILLION (ppm): One part per million is equivalent to one minute in two years or one penny in \$10,000.

PARTS PER BILLION (ppb): One part per billion is equivalent to one minute in 2,000 years or one penny in \$10,000,000.


NEPHELOMETRIC TURBIDITY UNIT (NTU): Turbidity is a measure of the cloudiness of water. We monitor turbidity because it is a good indicator of the effectiveness of our filtration system.

NON DETECT (ND): The contaminant was not present or was below the detection limits of the testing procedure.

Learn More About Water Issues

Be an active part of your community and learn more about water issues in Forsyth County by attending the Board of Commissioners meetings, held the first and third Thursday of each month. Meetings begin at 5 p.m. at 110 E. Main Street, Suite 220, Cumming, Georgia 30040.

EFFECTS OF LEAD IN WATER



If present, elevated lead levels can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Forsyth County Water & Sewer Department is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When water has been sitting for several hours, you can minimize the potential for lead exposure by flushing the tap for 30 seconds to two minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may want to have it tested. Information about lead in water, testing methods and steps to take to minimize lead exposure is available from the Safe Drinking Water Hotline or at:

<http://www.epa.gov/safewater/lead>

CONTACT US • Comments and questions are welcomed. Contact John Marshall, Forsyth County Water & Sewer Department, 110 E. Main Street, Suite 150, Cumming, Georgia 30040. Call (678) 455-8462 or fax (770) 781-2163. Visit the department webpage at forstco.com.

En Español: Este informe contiene información muy importante. Para obtener una copia del mismo en español escriba a la siguiente dirección: Forsyth County Water & Sewer Department, 110 E. Main Street, Suite 150, Cumming, Georgia 30040.